

OMRON

Smart Fiber Amplifier
E3NX-FA□□AN

INSTRUCTION SHEET


Thank you for selecting an OMRON product. This sheet primarily describes precautions required in installing and operating the product.



© OMRON Corporation 2017 All Rights Reserved. (2/4)


1 Installation

1-1 Dimensions




Unit: mm. Dimensions in parentheses () indicates the ones with related components. The cover could come off if it is tilted by 170 degrees or more.


1-2 Input/Output Circuit Diagram



1-3 Mounting the Amplifier Unit




1-4 Mounting Fiber Unit




2 Settings

2-1 Setting and Display Overview




2-3 Smart Tuning [Easy Sensitivity Setting]


① Detecting Presence/Absence of Workpiece




② Increasing Resistance to Dust and Dirt




③ Making Adjustment with Moving Workpiece without Stopping the Line



④ Determining the Workpiece Position



⑤ Detecting a Transparent or Microscopic Object (Setting a Threshold with Received Light Intensity Ratio)



⑥ Restoring the Received Light Intensity Weakened due to Dust or Dirt / Restoring the Saturated Received Light Intensity



● Smart Tuning Error

Table with 3 columns: Error / Display, Cause, and Remedy. It lists errors like nERr, auEr Err, and Lo Err with their causes and how to resolve them.

2-2 Output switching


Press [L/D] button.

Through-beam: Set to "Dark ON" to turn the output ON with a workpiece in the detection area.

[L/D Indicator] turns [D] ON.

Reflective: Set to "Light ON" to turn the output ON with a workpiece in the detection area.

[L/D Indicator] turns [L] ON.



WARNING Indicates a potentially hazardous situation which, if not avoided, will result in minor or moderate injury, or may result in serious injury or death. Additionally there may be significant property damage.

● Warning Indications

WARNING

This product is not designed or rated for ensuring safety of persons either directly or indirectly. Do not use it for such purpose.

Do not use the product with voltage in excess of the rated voltage. Excess voltage may result in malfunction or fire.


Never use the product with an AC power supply. Otherwise, explosion may result.

PRECAUTIONS FOR SAFE USE

- The following precautions must be observed to ensure safe operation of the product. Do not install the product in the following locations: (1) Locations subject to direct sunlight... (7) Locations subjected to strong magnetic field or electric field...

PRECAUTIONS FOR CORRECT USE

- Be sure to mount the unit to the DIN track until it clicks. When using a connector type product, place a protective label (provided with the E3X-CN series) on the power supply connecting terminals that are not used...



- The length for the cable extension must be 30 m or less (or less than 10 m for S-mark certified models). Do not apply the forces on the cord exceeding the following limits: Pull: 40N; torque: 0.1Nm; pressure: 20N; bending: 29 4N...

Checking the Package Content

- Amplifier Unit: 1 • Instruction Sheet (this sheet): 1 (Japanese, English, Chinese and Korean)

E3NX-FA□□AN

3 Convenient Setting Features

For Stable Detection Regardless of Received Light Intensity Changed due to Dust or Dirt

DPC Function
Use of the DPC function with through-beam model or regressive reflection model is recommended.

The DPC indicator turns ON when the DPC function is effective.

Smart Tuning → SET mode → DPC Function ON

Refer to "2-Settings".

When smart tuning is in error/maximum sensitivity tuning is executed/the 1st point of the position tuning is smaller/area check/detection mode, the DPC function is disabled.

Initializing Settings

Setting Reset Initialize all settings to the factory-set defaults.

Hold both for 3 sec. or longer

Saving/Reading Settings

User Save Function/User Reset Function

User Save Function → [SAvE] → [SAvE nO] → [SAvE yES]

User Reset Function → [rSt] → [rSt nO] → [rSt USEr]

Hold both for 3 sec. or longer

Preventing Malfunction

Key Lock Function Disables all the button operations.

Enable/Cancel (The same procedure)

Hold both for 3 sec. or longer

Press either of UP/DOWN.

4 Maintenance

4-1 Troubleshooting

Problem	Cause	Remedy
Nothing is shown on the indication.	No power supplied or the cable broken	Check the wiring, connector connection, power supply voltage and power supply capacity again. *1
Nothing is shown on the digital indication.	Eco mode is ON.	Turn OFF Eco mode. *2
Sensing/Detection not possible despite the minimum threshold level	Detection set to a small light level mode Dust or dirt influences	Setting GIGA Mode increases emission power and light intensity. *2
The OUT indicator blinking	Mutual interference or other reason	Check the Amplifier Units mounted in a group and turn ON the power again. *3
Incident light level displayed in a negative value	The zero reset function is enabled.	Cancel the zero reset function. *4
Lost tracking of the settings made	-	Reset the settings. *4
The light intensity level display changes.	Affected by dust or dirt, temperature change, vibration, etc.	Use of the DPC function makes the light intensity level display stable. *4

*1 Refer to "1-2 Input/Output Circuit Diagram" *2 Refer to "3-Detailed Settings".
*3 Refer to "1-3 Mounting Amplifier Unit" *4 Refer to "3-Convenient Setting Features"

Error Name / Display	Cause	Remedy
DPC Error ¹ 20004000	The incident light level has deteriorated due to dust or dirt.	Wipe the dust off the Fiber Unit detection surface or other relevant areas and recover the original incident light level. Then, perform Smart Tuning. *2
EEPROM time-out error E-nE 01	Failed internal data read/out	Turn ON the power again. Reset the settings if the error is not corrected. *3
EEPROM checksum error E-nE 02	Failed internal data read/out	Turn ON the power again. Reset the settings if the error is not corrected. *3
Lock ON LoC on	The key lock function enabled	Cancel the key lock function. *3
Load short circuit detection error E-St	Over current flowing to the control output	Check wiring and connector connection again. *4

*1 The DPC indicator blinks. *2 Refer to "2-3 Smart Tuning"
*3 Refer to "3-Convenient Setting Features" *4 Refer to "1-2 Input/Output Circuit Diagram" and "4-2 Ratings and Specifications"

Returning Received Light Intensity Display to "0"

Zero Reset Function

Enable: Hold both for 3 sec. or longer

Cancel: Hold both for 3 sec. or longer

The threshold also changes accordingly. The lower threshold limit is -1999.

For Output When Received Light Intensity is Within the Area

Area Detection Mode

- Select [Setting Mode] - [OUT1 Mode] - [Area Detection Mode]. Pressing the [MODE] button for 3 seconds or longer exits the SET mode.
- Press the [MODE] button in [Measurement Mode] to display "OUT1 HIGH" and "OUT1 LOW". Green digital indicator shows HIGH and LOW.
- Provide Smart Tuning to each of HIGH/LOW thresholds by pressing the [S.TUNE] button.

In tuning by percent, the thresholds are set as follows:
HIGH: Received light intensity in 3. × Absolute value of percent tuning level
LOW: Received light intensity in 3. × Absolute value of percent tuning level

Checking Received Light Intensity When Workpiece Passes at High Speed

Change finder

- Select [Setting Mode] → [Digital Display] to set [diSP CFdr].
- Pressing the [MODE] button for 3 seconds or longer exits the SET mode.
- Let the workpiece pass.
- Displays and retains the light intensity (maximum/minimum value) in white digital for 0.5 seconds when the workpiece passes.

Determining If Workpiece is Detectable

Solution Viewer

- Press both the [MODE] and [LD] buttons for at least 3 seconds to set to [SoLU on]. To release the setting, press the [MODE] and [LD] buttons for at least 3 seconds to set to [SoLU OFF].
- Let the workpiece pass.
- Passing time and light amount difference are displayed.
- Press the [MODE] and [LD] buttons at the same time for at least 3 seconds to exit setting mode.

5 Detailed Settings

Hold [MODE] button for 3 seconds or longer to enter SET mode.

SET mode provides the following function settings. The initial display shown after transition from one function to another represents the factory default.

- Function Selection** Changing 6 to 14
Basic setting: [Func dFLt] → Detailed setting: [Func oPt]
- Detection Function** Changing Light Level and Response Time
HS High-speed Mode: [HS 500] → STND Standard Mode: [Stnd 500] → GIGA Giga Mode: [GIGA 4000] → SHS Super High-speed Mode: [SHS 125]
- DPC Function** Stable Detection Regardless of Incident Light Level Change
DPC OFF: [dPC OFF] → DPC ON: [dPC on]
- Timer Function** Setting Output Timer
Time Off: [tOff ----] → (a) Off-delay Timer: [offd 10] → (b) On-delay Timer: [on-d 10] → (c) One-shot: [Shot 10] → (d) On Off-delay Timer: [onof ----]
- Power Tuning Level** Changing the Target Incident Light Level (Power Tuning Level)
Use [MODE] button to set the power tuning level. (100 to 9999 in 1 steps; the initial value: 9999)
P-Lu 9999

- BANK Switching** Set values are saved for each configured bank.
BANK1: [bAnL 1] → BANK2: [bAnL 2] → BANK3: [bAnL 3] → BANK4: [bAnL 4]
- Power Tuning ON/OFF Setting** To Turn ON/OFF the Light Amount Adjustment at Tuning
Power tuning adjustment ON: [PtUn on] → Power tuning adjustment OFF: [PtUn off]
- Percentage Tuning** Detecting Transparent or Microscopic object
Percentage tuning OFF: [PEr OFF] → Percentage tuning ON: [PEr on]
- Output 1 Mode** Output mode for the output 1 is changed.
Normal detection mode: [out Std] → Area detection mode: [out ArEA]
- Output 2 Mode** Output mode for the output 2 is changed.
Analog scaling: [out SCAL] → Analog offset: [out oFSE]

- Digital Display** Changing Digital Display in RUN Mode for Specific Purpose
Threshold/Receiving light amount: [d.iSP Std] → [d.iSP PEr] → [d.iSP P-b] → [d.iSP bAr] → [d.iSP CFdr] → [d.iSP CH] → [d.iSP PERL]
- Inverted Display** Mounting Amplifier in Inverted Direction
Normal: [rEv OFF] → Reverse: [rEv on]
- Eco Function** Saving Power Consumption
Eco on: [ECo OFF] → Eco function ON: [ECo on] → Eco function LO: [ECo Lo]
- Hysteresis width**
Standard setting: [HStd 37] → User setting: [HUsr 37]

Suitability for Use

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM. See also Product catalog for Warranty and Limitation of Liability.

OMRON Corporation	Industrial Automation Company
Tokyo, JAPAN	Contact: www.ia.omron.com
Regional Headquarters	
OMRON EUROPE B.V. Sensor Business Unit Carl-Benz-Str. 4, D-71154 Nufringen, Germany Tel: (49) 7032-811-0/Fax: (49) 7032-811-199	
OMRON ELECTRONICS LLC 2895 Greenspoint Parkway, Suite 200 Hoffman Estates, IL 60169 U.S.A. Tel: (1) 847-843-7900/Fax: (1) 847-843-7787	
OMRON ASIA PACIFIC PTE. LTD. No. 438A Alexandra Road # 05-05/08 (Lobby 2), Alexandra Technopark, Singapore 119967 Tel: (65) 6835-3011/Fax: (65) 6835-2711	
OMRON (CHINA) CO., LTD. Room 2211, Bank of China Tower, 200 Yin Cheng Zhong Road, PuDong New Area, Shanghai, 200120, China Tel: (86) 21-5037-2222/Fax: (86) 21-5037-2200	

D Oct, 2014

OMRON


智能光纤放大器

型号 E3NX-FA□□AN

使用说明书

感谢您购买本产品，谨致敬意。
使用时请务必遵守以下内容。

- 请具备电气知识的专业人员实施操作。
- 请在阅读并理解本说明书的基础上正确使用。
- 请妥善保管本说明书，以备随时查阅。



欧姆龙有限公司
© OMRON Corporation 2017 All Rights Reserved. (3/4)

警告

若使用不当，则可能会造成轻伤、中等程度伤害，有时甚至可能导致重伤或死亡。此外，还可能带来重大的经济损失。

警告

请勿出于安全目的将本产品直接或间接使用在人体检测用途上。也勿使用在人体保护用的检测装置上。

可能会引起故障或火灾。使用时，请勿超过额定电压。

可能会导致产品破裂。严禁在AC电源下使用。


安全要点

为了确保您的安全，请务必遵守以下内容。否则可能会引起损坏或火灾。

- 请勿在以下环境中使用。
 - ① 阳光直射的场所
 - ② 湿度高、易结露的场所
 - ③ 有腐蚀性气体的场所
 - ④ 振动或冲击超出额定范围的场所
 - ⑤ 有水、油、化学药品等飞溅的场所
 - ⑥ 接触到蒸气的场所
 - ⑦ 强电场、强磁场的场所
- 请勿在有易燃、易爆气体的环境下使用。
- 请勿在超出额定范围的环境下使用。
- 请将传感器设置在远离高压或动力设备的地方，以免操作或维护时发生危险。
- 请将传感器和高压线、动力线分开布线。若使用同一排线槽或在同一排线槽内排线，会相互感应，引起错误动作或破损。
- 请确保负载在额定范围以下使用。否则可能会引起损坏或火灾。
- 请勿让负载短路。否则可能会引起损坏或火灾。
- 请正确连接负载。
- 请注意电源的极性，防止错误接线。
- 请勿在外壳破损的状态下使用。
- 可能会导致烫伤。根据使用条件（环境温度、电源电压等）不同，传感器表面温度会升高，操作或清扫时请多加注意。
- 设定传感器时请停止装置运行，确认安全后再执行操作。
- 请务必切断电源后再安装或拆卸导线。
- 请勿擅自拆卸、修理、改造本产品。
- 废弃时，请作为工业废弃物处理。
- 请勿在水中、雨中、及室外使用。
- 请在 IP54 的护栏中使用。
- 关于 UL 标准认证
 - 只有标有认证标记的产品，才是取得 UL 成品认证的商品。前提是在 Class 2 回路中使用。
 - 在美国、加拿大地区使用时，请将输入/输出端接在同一个 Class 2 回路上。过电流保护的最大限度是 2A。作为开路型商品进行评价。要放置在设备内使用。

使用注意事项

- 安装至 DIN 导轨时，请推压放大器直至钩爪完全嵌入导轨。
- 使用连接器型产品时，为了防止触电或短路，请在不使用的电源连接端子上，贴上保护用贴片。（连接器：E3X-CN 系列的附属品）




- 请确保延长导线在 30m 以下（S 标志认证为 10m 以下）。请使用截面积为 0.3mm² 以上的延长导线。通过加长电源线及省配线连接器连接放大器单元时，请使用 24 ~ 30V 的电源电压。
- 施加于导线部的力请确保在以下范围内。
 - 拉伸 40N 以下、扭矩 0.1N·m 以下、压紧力 20N 以下、弯曲时受重 29.4N 以下。
- 光纤固定于放大器状态下，请勿对其强行施加拉伸力、压缩力、扭转力等。
- 请务必安装保护罩后使用。可能会导致错误操作。
- 接通电源后，由于周围环境不同，到受光量/测定值安定为止可能需要一定时间。
- 接通电源后经过 200ms 即可检测。
- 无法连接手持式控制器型号 E3X-MC11、E3X-MC11-SV2、E3X-MC11-S。
- 无法与型号 E3C、E2C、E3X 之间启用相互干涉防止功能。
- 若接收过多的其他传感器发出的光量，相互干涉防止功能可能会无法充分发挥作用，发生误动作。此时请调大阈值。
- 无法连接通信单元型号 E3X-DRT21-S、E3X-CRT、E3X-ECT、E3NW。
- 万一感觉异常时，请立即切断电源停止使用，并联系本公司或代理商。
- 请勿使用稀释剂、汽油、丙酮、煤油类溶剂清洁。

包装内容确认

• 放大器 1 台 • 使用说明书（本说明书）日语、英语、中文、韩语子 各 1 份。


1 设置

1-1 外形尺寸图



① 内的尺寸为相关部件的配合尺寸。
保护罩打开角度超过 170 度时可能会脱落。


1-2 输入输出端电路图



1-3 放大器的安装

■安装至 DIN 导轨

- (1) 如右图所示，将光纤插入一侧的钩爪嵌入导轨。
- (2) 往后下方推压放大器，直至钩爪完全锁定。
DIN 导轨（型号 PFP-□N）另售。



1-4 光纤的安装

■光纤切割刀的使用方法

- (1) 将光纤插入刀孔。
- (2) 一次按下刀刃，切断光纤。


■光纤的安装

- (1) 打开保护罩。
- (2) 提起光纤锁定拨杆。（解锁）
- (3) 确保光纤插入到放大器光纤插入口的最底部。
- (4) 还原锁定拨杆，固定光纤。（锁定）

- 安装细径光纤时，需要使用该光纤附属品，型号 E39-F9（同捆于相应的光纤中）。
- 如右图所示，安装同轴反射型光纤时，请将单芯光纤插入传感器的上孔（投光部分），将多芯光纤插入下孔（受光部分）。

2 设定

2-1 操作·显示一览表



2-2 L/ON、D/ON输出切换方法

L/ON 键进行设定。

对射型：要让传感器在有工件时进入 ON 状态，请设定为“Dark ON” [L/D 指示灯] 的 **L** 亮灯。

反射型：要让传感器在有工件时进入 ON 状态，请设定为“Light ON” [L/D 指示灯] 的 **L** 亮灯。

2-3 智能调整【灵敏度的简单调整】

① 想要检测有/无检测物体

● 两点示教
受光量的自动设定：将两点示教中受光量较大的值，调整到“光量调整值”
阈值的自动设定：两点示教的受光量的中间值
松开按键后即显示「2Pnt」

② 想要加强防尘抗污力

● 最大灵敏度调整
受光量的自动设定：将按键时的受光量调整到“0”
阈值的自动设定：按键时受光量的 7% 左右
长按 3 秒以上
显示「FULL」后再松开按键

③ 想要不停止运行、通过移动的检测物体进行调整

● 全自动调整
受光量的自动设定：将按键过程中的最大受光量，调整到“光量调整值”
阈值的自动设定：按键过程中的最大/最小受光量的中间值
长按 7 秒以上
工件通过后松开按键

④ 想要确定检测物体的位置

● 定位调整
受光量的自动设定：将待检位置时的受光量，调整到“光量调整值”的一半
阈值的自动设定：待检位置时的受光量的相同值
松开按键后即显示「2Pnt」
长按 3 秒以上

⑤ 想要检测透明物体或微小物体(想要通过受光量比率设定阈值)

● 百分比调整
受光量的自动设定：将无工件状态下的受光量，调整到“光量调整值”
阈值的自动设定：(上述设定的受光量 × 百分比调整值)
开启百分比调整功能
无工件状态下
长按 1 秒以上

⑥ 想要将灰尘或污垢导致的受光量变化/饱和状态的受光量还原时

● 光量调整
受光量的自动设定：将按键时的受光量，调整到“光量调整值”
阈值的自动设定：不作变化
反射型放大器请在有工件状态下进行设定。
定位调整已开启状态下，对射型或反射型都请在有工件状态下进行设定。
同时按 1 秒以上

2-4 微调阈值



●智能调整的错误代码

错误名/显示	原因	对策
Near Error nER Err	调整过程中受光量差值过小	• 请设定为响应速度较慢的检测模式 • 请减少投受光间的距离(对射型) • 请减少光纤头部和工件的距离(反射型)
Over Error ouEr Err	受光量过大	• 请增大投受光间的距离(对射型) • 请增大光纤头部和工件的距离(反射型) • 请使用细径光纤
Low Error Lo Err	受光量过小	• 请减小投受光间的距离(对射型) • 请减小光纤头部和工件的距离(反射型)

